

To: AUTHORISED DEALERS/DISTRIBUTORS  
N.Z. APPROVED INSTALLERS  
H.O., REG'L & AUST. MANAGERS  
APPLIC. NOTICE GENERAL LIST

Issue No.: 02/01  
Date: 11<sup>th</sup> January 2001  
From: T King/K Edwards

Subject: HANWEST CONTROLS APPLIED TO TEMPERZONE UNITS  
Units: ALL SPLIT & PACKAGED AIR COOLED UNITS

Attached is a data sheet 1896 (09/00) showing the wiring requirements when connecting HANWEST Controllers to temperzone Split System Units. The diagrams on the data sheet refer to split units but diagrams Fig. 2 and Fig. 6 can equally be applied to OPA units. Use Fig. 2 for OPA101, 150 & 180, and Fig. 6 for OPA210-920.

Please note that each diagram also details which links should and should not be removed to suit the control voltage and fan motor voltage.

For further information relating to remote sensors, averaging sensors or any other special requirement, refer the HanWest Data and Installation Sheets for connections and dip switch setting changes.